

15743

Monsanto

FROM
(NAME-LOCATION-PHONE) T. Carrico, Ext. 2095

| | | |
|-----------|---------------------------|-----------------------|
| DATE | July 15, 1985 | cc. L. Bumbicka |
| | | K. Lichtenheld - CS6G |
| SUBJECT | Status Report on CEA 3808 | R. Nelson |
| | | K. Petterson |
| REFERENCE | | O. Shipley |
| | | B. Stekatee |
| TO | P. Hoemann | |

Repair began on L-35 lateral.

Manhole 1BB primed-transite building in place.

Manhole 1CC is still not acceptable for prime coat.


1DD okayed on water test and epoxy coating applied - some backfill.

L-43 base poured and tile in place.

L-46 and 2AA bases poured.

Started making joints again between 1DD and 1EE on July 10.

Tracks 8B and 8D back in service on July 12.


T. Carrico
Operation Foreman

skg

WGK 4084694

IN-1120